شركة بشائر البناء للمقاولات
Bashaer Al-Benaa Contracting Company

ECEC شركة الشرق للاستشارات الهندسية
East Consulting Engineering Company

الهيئة السعودية للسياحة
SAUDI TOURISM AUTHORITY

Site:	FITOUT PROJECT AL-RAED RIYADH	WIR -Area- Bldg site - Disc	REQUEST No.	089	Rev.# Of Copies 1
			Serial	BBC-ECE-AR-WIR-010-R01	
To:	CONSULTANT	Date:	01/01/2023		

WORK INSPECTION REQUEST

We hereby request the Engineer's attendance to inspect the following work:

Level of Inspection: ☐ Hold ☐ Witness ☐ Release Inspection ☑ Handing Over

Location of Inspection: 4th Floor

Reference Documents and Attachments: .....

Specification #: ☐ **MIR #:** ☐ **Inspection Checklist #:** ☐ **Certificate:** ☐

Clearance & Releases: ☐ **Marked-up Approved Shop Drawings:** ☐

Activity ID/BOQ.: ..... **Date & Time of Inspection:** .....

Previous Inspection History: .....

Meeting Notes #: ..... **Testing Results:** ..... **Issued NCR #:** .....

Description of Work:	**Frist Leyer of block works for 4th Floor**
Contractor's QC Report:	**works conforms to specifications**

We certify that the submitted work for inspection has been executed in accordance with the contract's specification and approved shop drawings.

PM. Name:	Eng.tarek Reafaei	**Signature:**	**Date:** 1-01-2023
Surveyor:	Eng.Sabry	**Signature:**	**Date:**
DC. Name:	Ahmed Gamal	**Signature:**	**Date:** 1/1/2023

Engineer's Inspection Comment:

* CHECK COMMENTS WITH ATTACHED DWG.
* ELECTRICAL PANEL ROOM HOLD TILL FINALIZE THE SIZE OF DOOR / AS PER ACTUAL SITE DOOR OPENING SPACE / SWING IN NOT ENOUGH.
* SHOULD ATTACHED APPROVED S.D
* ANY HORIZANTAL MARKING OF POINT MISTAICE SURVEYOR WILL BE RESPONSIBLE.

Inspection Status:

A - Approved / Proceed ☐ **B - Approved with comments** ☑ **C - Rejected** ☐

Name: ..... **Signature:** ..... **Date:** 3/1/2023

STA PM:

Name: ..... **Signature:** ..... **Date:** 03/01/2023

Client Representative:

Name: ..... **Signature:** ..... **Date:** 3-1-23

Contractor's Received: .....

Received by: ..... **Signature:** .....

Acceptance of the request does not relieve the contractor from full compliance with the requirements of the contract's documents, dimensions selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner and correlating all quantities and conformance with the design concept of the project and general compliance with the information given in the contract documents

All requests must be submitted at least 24 hours prior to the required inspection and approval.

CC: ☐ **AM** **QA/QC** ☐

Area: .....

Site: .....

Discipline: .....

2.1.23
2:46

3/1/2-23